

Bryan's Water Quality store LLC
 1860 8th Street So.
 Wisconsin Rapids, WI 54494
 Phone 715-422-4770
 Fax 715-422-4770

NAME: _____
 PHONE: _____
 ADDRESS: _____
 CITY: _____
 DATE: 8-1-16

	<i>Am Shower</i>	<i>Last night 10 buckets</i>	<i>After shower</i>
HARDNESS			
PH			
IRON	<i>6ppm</i>	<i>4ppm</i>	<i>2ppm</i>
TDS			
NITRATES			
Was the water clean when it was drawn?			

GRAS: Generally Recognized As Safe
EPA: Environmental Protection Agency (Fed)

Was there an	GRAS per EPA: 0.3 ppm		
	6.0 ppm	4.0 ppm	2.0 ppm
over GRAS:	2000%	1333%	667%
before shower 6.0 ppm; run 'til clear=2.0ppm at end of shower			